

Zayibeth Carballo

From: Louis Reynolds
Sent: Wednesday, April 9, 2025 10:39 AM
To: Zayibeth Carballo
Subject: 745 Northfield Ave

Follow Up Flag: Flag for follow up
Flag Status: Flagged

At 7:20 am this morning. A call was made to me about an apparent water main break at this location.

DPW personnel were dispatched to investigate the situation.

Turns out , it is a sewer force main break. DPW sewer crew were dispatched. Along with a call I made to Grabowski construction contractors. Contractor responded in 15 minutes. To assess the situation. Called in emergency markouts . DPW sewer supervisor was asked to call Rapid pump for two Vactor tank trucks .

To abate and relieve the high flow of sewer water discharge . As many areas of sewer water collection are directed to this force main .


This process , is still in the works . In affording repairs .

Louis Reynolds, CPWM

Director of Public Works
Township of West Orange
25 Lakeside Avenue
West Orange. NJ 07052
Office 973-325-4067

Lreynolds@westorange.org

www.westorange.org



Please consider the environment before you print this email
America, Land of the Free, Because of the Brave!

Confidentiality Notice: This e-mail contains information from the Township of West Orange. It is intended only for the person or entity to which it is addressed and may contain information that is privileged, confidential or otherwise protected from disclosure. Dissemination, distribution or copying of this e-mail or the information contained within it by anyone other than the intended recipient or an employee or agent responsible for delivering the message to the intended recipient is prohibited. If you have received this e-mail in error, please call 973-325-4067 and destroy the original message and all copies.